Page 1 of 29

Permit No.: WA-005233-8

Issuance Date: Effective Date: Expiration Date:

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM WASTE DISCHARGE PERMIT NO. WA-005233-7

STATE OF WASHINGTON DEPARTMENT OF ECOLOGY YAKIMA, WASHINGTON 98902

In compliance with the provisions of
The State of Washington Water Pollution Control Law
Chapter 90.48 Revised Code of Washington
and
The Federal Water Pollution Control Act
(The Clean Water Act)
Title 33 United States Code, Section 1251 et seq.

CITY OF TONASKET PO BOX 487 TONASKET, WA 98855

<u>Plant Location</u>: 500 Railroad Avenue <u>Receiving Water</u>: Okanogan River

Water Body I.D. No.:

WA-49-1020

Discharge Location:

Latitude: 48° 42' 09" N

Longitude: 119° 26' 55" W

Plant Type: Extended Aeration, Activated

Sludge

is authorized to discharge in accordance with the special and general conditions that follow.

Richard J. Frye
Acting Section Manager
Water Quality Program
Central Region Office
Washington State Department of Ecology

tonasket p 1-23-06 January 23, 2006 8:53 AM rich marcley



TABLE OF CONTENTS

		Page
SUMMA	RY OF PERMIT REPORT SUBMITTALS	4
SPECIAL	_ CONDITIONS	5
S1.	DISCHARGE LIMITATIONS	
A.	Effluent Limitations	
B.	Mixing Zone	5
S2.	MONITORING REQUIREMENTS	
A.	Wastewater Monitoring	
B.	Ground Water Monitoring	7
C.	Sampling and Analytical Procedures	8
D.	Flow Measurement	8
E.	Laboratory Accreditation	8
F.	Request for Reduction of Monitoring	
S3.	REPORTING AND RECORDKEEPING REQUIREMENTS	
A.	Reporting	
B.	Records Retention	9
C.	Recording of Results	
D.	Additional Monitoring by the Permittee	
E.	Twenty-four Hour Notice of Noncompliance Reporting	
F.	Other Noncompliance Reporting.	
G.	Maintaining a Copy of This Permit	
S4.	FACILITY LOADING	
A.	Design Criteria	
В.	Duty to Mitigate	
C.	Notification of New or Altered Sources	
D.	Infiltration and Inflow Progress Reports	
S5.	OPERATION AND MAINTENANCE	
A.	Certified Operator	
B.	O & M Program	
C.	Short-term Reduction	
D.	Electrical Power Failure	
E.	Prevent Connection of Inflow	
F.	Bypass Procedures	
G.	Operations and Maintenance Manual	
S6.	PRETREATMENT	
A.	General Requirements	
В.	Wastewater Discharge Permit Required	17

Page 3 of 29

Permit No.: WA-005233-8

Expiration Date:

C.	Identification and Reporting of Existing, New, and Proposed Industrial Users	17
D.	Duty to Enforce Discharge Prohibitions	
S7.	RESIDUAL SOLIDS	
S8.	APPLICATION FOR PERMIT RENEWAL	19
S9.	COMPLIANCE SCHEDULE	20
A.	Scope of Work	20
B.	Progress Reports	20
C.	Final Report	20
GENER	AL CONDITIONS	22
G1.	SIGNATORY REQUIREMENTS	22
G2.	RIGHT OF INSPECTION AND ENTRY	23
G3.	PERMIT ACTIONS	23
G4.	REPORTING PLANNED CHANGES	24
G5.	PLAN REVIEW REQUIRED	
G6.	COMPLIANCE WITH OTHER LAWS AND STATUTES	25
G7.	TRANSFER OF THIS PERMIT	
G8.	REDUCED PRODUCTION FOR COMPLIANCE	
G9.	REMOVED SUBSTANCES	
G10.	DUTY TO PROVIDE INFORMATION	
G11.	OTHER REQUIREMENTS OF 40 CFR	
G12.	ADDITIONAL MONITORING	
G13.	PAYMENT OF FEES	
G14.	PENALTIES FOR VIOLATING PERMIT CONDITIONS	
G15.	UPSET	
G16.	PROPERTY RIGHTS	
G17.	DUTY TO COMPLY	
G18.	TOXIC POLLUTANTS	
G19.	PENALTIES FOR TAMPERING	
G20.	REPORTING ANTICIPATED NON-COMPLIANCE	
G21.	REPORTING OTHER INFORMATION	
G22.	COMPLIANCE SCHEDULES	29

Page 4 of 29

Permit No.: WA-005233-8

Expiration Date:

SUMMARY OF PERMIT REPORT SUBMITTALS

Refer to the Special and General Conditions of this permit for additional submittal requirements.

Permit			First
Section	Submittal	Frequency	Submittal Date
S3.	Discharge Monitoring Report	Monthly	
S3.E.	Noncompliance Notification	As necessary	
S4.C.	Notification of New or Altered Sources	As necessary	
S4.D1	Infiltration and Inflow Evaluation	1/permit cycle	With application for permit renewal
S4.D4	Pressure Leak Test	1/permit cycle	October 31, 2008
S5.G.	Operations and Maintenance Manual Update	As necessary	
S7.	Sludge Accumulation Measurement	1/permit cycle	June 30, 2009
S8.	Application for permit renewal	1/permit cycle	One year prior to permit expiration
S9.	Schedule of Compliance PCB/DDT Analysis of Effluent & Sludge	1/permit cycle	May 15, 2006
S9.	Second Test of Sludge for PCB and DDT ^a	1/permit cycle	December 15, 2006
S9.	Third Test of Effluent & Sludge for PCB & DDT ^b	1/permit cycle	With application for permit renewal
S9.A.	Source Identification and Reduction Evaluation ^c : Scope of Work	1/permit cycle	March 31, 2007
S9.B.	Progress Reports	Every 6 months	September 15, 2007
S9.C.	Final Report	1/permit cycle	September 15, 2009
G1.	Signature Authorization/Delegation	as necessary	
G4.	Permit Application for Substantive Changes to the Discharge	As necessary	
G5.	Engineering Report for Construction or Modification Activities	As necessary	
G21.	Notice of Planned Changes	As necessary	
G22.	Report Anticipated Non-compliance	As necessary	

<sup>a A second test of the sludge only is required if the initial test proves negative for both PCB and DDT in the effluent and sludge samples.
b If the second test proves negative for PCB and DDT in the sludge then a third round of testing the effluent and sludge shall be conducted in 2010 and the results shall be submitted with the application for permit renewal.</sup>



c The Source Identification and Reduction Evaluation parts A,B, and C of the Compliance Schedule is required ONLY if either the effluent or sludge samples test positive for DDT or PCB.

Page 5 of 29

Permit No.: WA-005233-8

Expiration Date:

SPECIAL CONDITIONS

S1. DISCHARGE LIMITATIONS

A. Effluent Limitations

All discharges and activities authorized by this permit shall be consistent with the terms and conditions of this permit. The discharge of any of the following pollutants more frequently than, or at a level in excess of, that identified and authorized by this permit shall constitute a violation of the terms and conditions of this permit.

Beginning on **the effective date of this permit** and lasting through **the expiration date** the Permittee is authorized to discharge municipal wastewater at the permitted location subject to complying with the following limitations:


TECHNOLOGY BASED EFFLUENT LIMITATIONS: OUTFALL # 001			
Parameter	Average Monthly	Average Weekly	
Biochemical Oxygen	30 mg/L, 102.6 lbs/day	45 mg/L, 153.9 lbs/day	
Demand (5 day)			
Total Suspended Solids	30 mg/L, 102.6 lbs/day	45 mg/L, 153.9 lbs/day	
Fecal Coliform Bacteria	200/100 mL	400/100 mL	
pН	Daily minimum is equal to or greater than 6 and the daily maximum is		
less than or equal to 9.			
^a The average monthly and weekly effluent limitations are based on the arithmetic mean of the samples			

^a The average monthly and weekly effluent limitations are based on the arithmetic mean of the samples taken with the exception of fecal coliform, which is based on the geometric mean.

B. Mixing Zone

The chronic mixing zone shall not extend upstream more than 100 feet and downstream 303 feet. The acute mixing zone shall not extend upstream more than 10 feet and downstream more than 30.3 feet. The plume width shall be no more than 7.4 feet in the acute mixing zone and 23.4 feet in the chronic mixing zone.

The aquatic life dilution factors are: acute dilution factor **20.5:1** and chronic dilution factor **141.6:1**.





Page 6 of 29

Permit No.: WA-005233-8

Expiration Date:

S2. MONITORING REQUIREMENTS

A. Wastewater Monitoring

The sampling point for the influent will be at the influent headworks after the Parshall flume. The sampling point for the effluent will be after disinfection.

The Permittee shall monitor the wastewater according to the following schedule:

		Sample	Sampling	Sample
Parameter	Units	Point	Frequency	Type
Ammonia	mg/L	Effluent a	2/month ^b	24-hr composite ^c
Ammonia	lbs/day	Effluent	2/month	Calculation
BOD ₅	mg/L	Influent ^d	1/week ^e	24-hr composite
		Effluent	1/week	24-hr composite
BOD ₅	lbs/day	Influent	1/week	Calculation ^f
		Effluent	1/week	Calculation
BOD_5	% removal	Effluent	1/week	Calculation
TSS	mg/L	Influent	1/week	24-hr composite
		Effluent	1/week	24-hr composite
TSS	lbs/day	Influent	1/week	Calculation
		Effluent	1/week	Calculation
TSS	% removal	Effluent	1/week	Calculation
Total Residual Chlorine	mg/L	Effluent	As necessary ^g	Grab ^h
Total Residual Chlorine	lbs/day	Effluent	As necessary	Calculation
Dissolved Oxygen	mg/L	Effluent	3/week	Grab
Flow	MGD	Influent	Continuous	Measurement
		Effluent	Continuous	Measurement
Hardness	mg/L as CaCO ₃	Effluent	Quarterly ⁱ	Grab
pН	Standard Units	Influent	5/week ^j	"
		Effluent	5/week	"
Temperature	⁰ Centigrade	Effluent	5/week	"
Fecal Coliform Bacteria	# colonies/ 100 ml	"	1/week	"
Total Kjeldahl Nitrogen	mg/L	44	44	44
Total Phosphorous	mg/L	44	44	44
Sludge Depth	Feet and	Sludge	1/permit cycle k	Measurement/
	cubic feet	Storage		Calculation

^a "Effluent" means wastewater which is discharged into the Okanogan River.



b "2/month" means collected twice during each calendar month on a rotational basis throughout the weeks of each month.

Page 7 of 29

Permit No.: WA-005233-8

Expiration Date:

B. Ground Water Monitoring

The ground water monitoring schedule shall be included in Appendix C of the City's O&M manual. The following ground water monitoring schedule is required until such time and in the event that an amended Appendix C has been approved by the Department.

Parameter	Units	Monitoring Well	Sampling	Sample Type
			Frequency ^a	
Chloride	mg/L	#1, 3, & 6	1/quarter ^b	Grab ^c
Nitrate	mg/L as N	#1, 3, & 6	1/quarter	Grab
pН	Standard Units	#1, 3, & 6	1/quarter	Grab
Specific Conductivity	μmhos/cm	#1, 3, & 6	1/quarter	Grab
Temperature	°C	#1, 3, & 6	1/quarter	Grab
TDS	mg/L	#1, 3, & 6	1/quarter	Grab
TKN	mg/L as N	#1, 3, & 6	1/quarter	Grab
Water Level	Feet	#1, 3, & 6	1/quarter	Measurement

^a After completion of the first year of monitoring, the sampling frequency may be reduced by the Department of Ecology (Department) upon review of the collected data.



^c "24-hr. composite" means a series of, at least, four individual samples collected over a 24-hour period at selected intervals based on an increment of either flow or time, and combined into a single container to be subsequently analyzed as one sample.

^d "Influent" means the raw sewage from the collection system which enters the first treatment process of the POTW.

^e "1/week" means collected once each calendar week, and may exclude weekends and holidays, and on a rotational basis throughout the days of the week.

f "Calculation" means calculated using the respective sample's concentration. (mg/L) x 8.34 x flow = lbs/day.

g "As Necessary" means whenever chlorination is used for disinfection purposes, at a minimum of once per day.

h "Grab" means an individual sample collected in less than fifteen minutes.

ⁱ "Quarterly" means collected once during each calendar quarter, so that the samples are representative of the effluent throughout the quarter.

j "5/week" means collected five times during each calendar week, and may exclude weekends and holidays.

^k "1/permit cycle" means sludge shall be measured once during the permit cycle during the 2nd quarter of 2009.

b "1/quarter" means collected once during each calendar quarter on a rotational basis throughout the months of the vear.

^c "Grab" means an individual sample collected in less than fifteen minutes.

Page 8 of 29

Permit No.: WA-005233-8

Expiration Date:

C. Sampling and Analytical Procedures

Samples and measurements taken to meet the requirements of this permit shall be representative of the volume and nature of the monitored parameters, including representative sampling of any unusual discharge or discharge condition, including bypasses, upsets and maintenance-related conditions affecting effluent quality. Sampling and analytical methods used to meet the monitoring requirements specified in this permit shall conform to the latest revision of the *Guidelines Establishing Test Procedures for the Analysis of Pollutants* contained in 40 CFR Part 136. unless otherwise specified in this permit or approved in writing by the Department of Ecology (Department).

D. Flow Measurement

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the quantity of monitored flows. The devices shall be installed, calibrated, and maintained to ensure that the accuracy of the measurements are consistent with the accepted industry standard for that type of device. Frequency of calibration shall be in conformance with manufacturer's recommendations and at a minimum frequency of at least one calibration per year. Calibration records shall be maintained for at least three years.

E. Laboratory Accreditation

All monitoring data required by the Department shall be prepared by a laboratory registered or accredited under the provisions of, *Accreditation of Environmental Laboratories*, Chapter 173-50 WAC. Flow, temperature, settleable solids, conductivity, pH, and internal process control parameters are exempt from this requirement. Conductivity and pH shall be accredited if the laboratory must otherwise be registered or accredited. The Department exempts crops, soils, and hazardous waste data from this requirement pending accreditation of laboratories for analysis of these media.

F. Request for Reduction of Monitoring

The Permittee may request the Department of Ecology (Department) review the data to determine whether a reduction of the sampling frequency is warranted after 12 months of monitoring. The request shall: (1) be in written form, (2) clearly state the parameters for which the reduction in monitoring is being requested, and (3) clearly state the justification for the reduction. Any request for reduction in monitoring shall be granted



Page 9 of 29 Permit No.: WA-005233-8 Expiration Date:

at the Department's discretion and accomplished through an Administrative Order or permit modification.

S3. REPORTING AND RECORDKEEPING REQUIREMENTS

The Permittee shall monitor and report in accordance with the following conditions. The falsification of information submitted to the Department shall constitute a violation of the terms and conditions of this permit.

A. Reporting

The first monitoring period begins on **the effective date of the permit**. Monitoring results shall be submitted monthly. Monitoring data obtained during each monitoring period shall be summarized, reported, and submitted on a Discharge Monitoring Report (DMR) form provided, or otherwise approved, by the Department. DMR forms shall be postmarked or received by the Department no later than the 15th day of the month following the completed monitoring period, unless otherwise specified in this permit.

Priority pollutant analysis data shall be submitted no later than 45 days following the monitoring period. Unless otherwise specified, all toxicity test data shall be submitted within 60 days after the sample date. The report(s) shall be sent to:

Permit Data Systems Manager
Department of Ecology
Central Regional Office
15 West Yakima Avenue, Suite 200
Yakima, Washington 98902

Discharge Monitoring Report forms must be submitted monthly whether or not the facility was discharging. If there was no discharge during a given monitoring period, submit the form as required with the words "no discharge" entered in place of the monitoring results.

B. Records Retention

The Permittee shall retain records of all monitoring information for a minimum of 3 years. Such information shall include all calibration and maintenance records and all original recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this



Page 10 of 29

Permit No.: WA-005233-8

Expiration Date:

permit. This period of retention shall be extended during the course of any unresolved litigation regarding the discharge of pollutants by the Permittee or when requested by the Department.

C. Recording of Results

For each measurement or sample taken, the Permittee shall record the following information: (1) the date, exact place, method, and time of sampling or measurement; (2) the individual who performed the sampling or measurement; (3) the dates the analyses were performed; (4) the individual who performed the analyses; (5) the analytical techniques or methods used; and (6) the results of all analyses.

D. Additional Monitoring by the Permittee

If the Permittee monitors any pollutant more frequently than required by this permit using test procedures specified by Special Condition S2 of this permit, then the results of such monitoring shall be included in the calculation and reporting of the data submitted in the Permittee's DMR.

E. Twenty-four Hour Notice of Noncompliance Reporting

- 1. The Permittee must report the following occurrences of noncompliance by telephone, to Ecology at 509.575.2490, within 24 hours from the time the Permittee becomes aware of the circumstances:
 - a. any noncompliance that may endanger health or the environment;
 - b. any unanticipated bypass that exceeds any effluent limitation in the permit (See Part S5.F., "Bypass Procedures");
 - c. any upset that exceeds any effluent limitation in the permit (See G.15, "Upset");
 - d. any violation of a maximum daily or instantaneous maximum discharge limitation for any of the pollutants in S1.A.; or
 - e. any overflow prior to the treatment works, whether or not such overflow endangers health or the environment or exceeds any effluent limitation in the permit.



Page 11 of 29

Permit No.: WA-005233-8

Expiration Date:

2. The Permittee must also provide a written submission within five days of the time that the Permittee becomes aware of any event required to be reported under subpart 1, above. The written submission must contain:

- a. a description of the noncompliance and its cause;
- b. the period of noncompliance, including exact dates and times;
- c. the estimated time noncompliance is expected to continue if it has not been corrected:
- d. steps taken or planned to reduce, eliminate, and prevent recurrence of the noncompliance; and
- e. if the non compliance involves an overflow prior to the treatment works, an estimate of the quantity (in gallons) of untreated overflow.
- 3. Ecology may waive the written report on a case-by-case basis if the oral report has been received within 24 hours of the noncompliance.
- 4. Reports must be submitted to the address in S3.("REPORTING AND RECORDKEEPING REQUIREMENTS").

F. Other Noncompliance Reporting.

The Permittee must report all instances of noncompliance, not required to be reported within 24 hours, at the time that monitoring reports for S3.A ("Reporting") are submitted. The reports must contain the information listed in paragraph E above, ("Twenty-four Hour Notice of Noncompliance Reporting"). Compliance with these requirements does not relieve the Permittee from responsibility to maintain continuous compliance with the terms and conditions of this permit or the resulting liability for failure to comply.

G. Maintaining a Copy of This Permit

A copy of this permit must be kept at the facility and be made available upon request to Department of Ecology inspectors.



Page 12 of 29

Permit No.: WA-005233-8

Expiration Date:

S4. FACILITY LOADING

A. Design Criteria

Flows or waste loadings of the following design criteria for the permitted treatment facility shall not be exceeded: (City of Tonasket Plans/Specs Wastewater Treatment Plant, February 2000, page 2 of 66.)

Average flow for the maximum month: 0.41 MGD BOD₅ loading for maximum month: 720 lbs/day TSS loading for maximum month: 550 lbs/day

B. Duty to Mitigate

The Permittee is required to take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit that has a reasonable likelihood of adversely affecting human health or the environment.

C. Notification of New or Altered Sources

The Permittee shall submit written notice to the Department whenever any new discharge or a substantial change in volume or character of an existing discharge into the POTW is proposed which: (1) would interfere with the operation of, or exceed the design capacity of, any portion of the POTW; (2) is not part of an approved general sewer plan or approved plans and specifications; or (3) would be subject to pretreatment standards under 40 CFR Part 403 and Section 307(b) of the Clean Water Act. This notice shall include an evaluation of the POTW's ability to adequately transport and treat the added flow and/or waste load, the quality and volume of effluent to be discharged to the POTW, and the anticipated impact on the Permittee's effluent [40 CFR 122.42(b)].

D. Infiltration and Inflow Progress Reports

1. The Permittee shall conduct an infiltration and inflow evaluation and **submit the report with its application for permit renewal.** Refer to the U.S. EPA publication, *I/I Analysis and Project Certification*, available as Publication No. 97-03 at: Publications Office, Department of Ecology, PO Box 47600, Olympia, WA, 98504-7600. Plant monitoring records may be used to assess measurable infiltration and inflow.



Page 13 of 29

Permit No.: WA-005233-8

Expiration Date:

2. If infiltration and inflow have increased by more than 15 percent from that found any previous report based on equivalent rainfall, the report shall contain a plan and a schedule for: (1) locating the sources of infiltration and inflow; and (2) correcting the problem.

- 3. Any infiltration or inflow identified in segments of the collection system which are under or adjacent to surface water shall be further characterized for the existence of exfiltration.
- 4. The portion of the collection system which operates at greater than atmospheric pressure shall be leak tested for exfiltration no later than **October 31, 2008.**

S5. OPERATION AND MAINTENANCE


The Permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed to achieve compliance with the terms and conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems, which are installed by a Permittee only when the operation is necessary to achieve compliance with the conditions of this permit.

A. Certified Operator

An operator certified for at least a Class II plant by the state of Washington shall be in responsible charge of the day-to-day operation of the wastewater treatment plant. An operator certified for at least a Class I plant shall be in charge during all regularly scheduled shifts.

B. O & M Program

The Permittee shall institute an adequate operation and maintenance program for its entire sewage system. Maintenance records shall be maintained on all major electrical and mechanical components of the treatment plant, as well as the sewage system and pumping stations. Such records shall clearly specify the frequency and type of maintenance recommended by the manufacturer and shall show the frequency and type of maintenance performed. These maintenance records shall be available for inspection at all times.





Page 14 of 29

Permit No.: WA-005233-8

Expiration Date:

C. Short-term Reduction

If a Permittee contemplates a reduction in the level of treatment that would cause a violation of permit discharge limitations on a short-term basis for any reason, and such reduction cannot be avoided, the Permittee shall give written notification to the Department, if possible, 30 days prior to such activities, detailing the reasons for, length of time of, and the potential effects of the reduced level of treatment. This notification does not relieve the Permittee of its obligations under this permit.

D. Electrical Power Failure

The Permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated wastes or wastes not treated in accordance with the requirements of this permit during electrical power failure at the treatment plant and/or sewage lift stations either by means of alternate power sources, standby generator, or retention of inadequately treated wastes. The Permittee shall maintain Reliability Class II (EPA 430-99-74-001) at the wastewater treatment plant, which requires primary sedimentation and disinfection.

E. Prevent Connection of Inflow

The Permittee shall strictly enforce its sewer ordinances and not allow the connection of inflow (roof drains, foundation drains, etc.) to the sanitary sewer system.

F. Bypass Procedures

Bypass, which is the intentional diversion of waste streams from any portion of a treatment facility, is prohibited, and the Department may take enforcement action against a Permittee for bypass unless one of the following circumstances (1, 2, or 3) is applicable.

1. Bypass for essential maintenance without the potential to cause violation of permit limits or conditions.

Bypass is authorized if it is for essential maintenance and does not have the potential to cause violations of limitations or other conditions of this permit, or adversely impact public health as determined by the Department prior to the bypass. The Permittee shall submit prior notice, if possible at least 10 days before the date of the bypass.



Page 15 of 29

Permit No.: WA-005233-8

Expiration Date:

2. Bypass which is unavoidable, unanticipated and results in noncompliance of this permit.

This bypass is permitted only if:

- a. Bypass is unavoidable to prevent loss of life, personal injury, or severe property damage. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities which would cause them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass.
- b. There are no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, stopping production, maintenance during normal periods of equipment downtime (but not if adequate backup equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventative maintenance), or transport of untreated wastes to another treatment facility.
- c. The Department is properly notified of the bypass as required in condition S3E of this permit.
- 3. Bypass which is anticipated and has the potential to result in noncompliance of this permit:

The Permittee shall notify the Department at least 30 days before the planned date of bypass. The notice shall contain: (1) a description of the bypass and its cause; (2) an analysis of all known alternatives which would eliminate, reduce, or mitigate the need for bypassing; (3) a cost-effectiveness analysis of alternatives including comparative resource damage assessment; (4) the minimum and maximum duration of bypass under each alternative; (5) a recommendation as to the preferred alternative for conducting the bypass; (6) the projected date of bypass initiation; (7) a statement of compliance with SEPA; (8) a request for modification of water quality standards as provided for in WAC 173-201A-110, if an exceedance of any water quality standard is anticipated; and (9) steps taken or planned to reduce, eliminate, and prevent reoccurrence of the bypass.

For probable construction bypasses, the need to bypass is to be identified as early in the planning process as possible. The analysis required above shall be considered during preparation of the engineering report or facilities plan and plans and specifications and shall be included to the extent practical. In cases where the probable need to bypass is determined early, continued analysis is necessary up to



Page 16 of 29 Permit No.: WA-005233-8

Expiration Date:

and including the construction period in an effort to minimize or eliminate the bypass.

The Department will consider the following prior to issuing an administrative order for this type bypass:

- a. If the bypass is necessary to perform construction or maintenance-related activities essential to meet the requirements of this permit.
- b. If there are feasible alternatives to bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, stopping production, maintenance during normal periods of equipment down time, or transport of untreated wastes to another treatment facility.
- c. If the bypass is planned and scheduled to minimize adverse effects on the public and the environment.

After consideration of the above and the adverse effects of the proposed bypass and any other relevant factors, the Department will approve or deny the request. The public shall be notified and given an opportunity to comment on bypass incidents of significant duration, to the extent feasible. Approval of a request to bypass will be by administrative order issued by the Department under RCW 90.48.120.

G. Operations and Maintenance Manual

The approved Operations and Maintenance Manual shall be kept available at the treatment plant and all operators shall follow the instructions and procedures of this manual.

The O&M Manual shall be reviewed by the Permittee at least annually. Substantial changes or updates to the O&M Manual shall be submitted to the Department whenever they are incorporated into the manual. Changes to the ground water monitoring schedule shall be approved by the Department.

In addition to requirements of WAC 173-240-080 (1) through (5) the O&M Manual shall include:

- 1. Emergency procedures for plant shutdown and cleanup in event of wastewater system upset or failure.
- 2. Wastewater system maintenance procedures that contribute to the generation of process wastewater.



Page 17 of 29

Permit No.: WA-005233-8

Expiration Date:

3. Any directions to maintenance staff when cleaning, or maintaining other equipment or performing other tasks which are necessary to protect the operation of the wastewater system (e.g. defining maximum allowable discharge rate for draining a tank, blocking all floor drains before beginning the overhaul of a stationary engine.)

- 4. The treatment plant process control monitoring schedule.
- 5. Ground water monitoring schedule.

S6. PRETREATMENT

A. General Requirements

The Permittee shall work with the Department to ensure that all commercial and industrial users of the publicly owned treatment works (POTW) are in compliance with the pretreatment regulations promulgated in 40 CFR Part 403 and any additional regulations that may be promulgated under Section 307(b) (pretreatment) and 308 (reporting) of the Federal Clean Water Act.

B. Wastewater Discharge Permit Required

The Permittee shall not allow significant industrial users (SIUs) to discharge wastewater to the Permittee's sewerage system until such user has received a wastewater discharge permit from the Department in accordance with Chapter 90.48 RCW and Chapter 173-216 WAC, as amended.

C. Identification and Reporting of Existing, New, and Proposed Industrial Users

- 1. The Permittee shall take continuous, routine measures to identify all existing, new, and proposed SIUs and potential significant industrial users (PSIUs) discharging or proposing to discharge to the Permittee's sewerage system (see Appendix B of Fact Sheet for definitions).
- 2. Within 30 days of becoming aware of an unpermitted existing, new, or proposed industrial user who may be an SIU, the Permittee shall notify such user by registered mail that, if classified as an SIU, they shall be required to apply to the Department and obtain a State Waste Discharge Permit. A copy of this notification letter shall also be sent to the Department within this same 30-day period.
- 3. The Permittee shall also notify all PSIUs, as they are identified, that if their classification should change to an SIU, they shall be required to apply to the



Page 18 of 29 Permit No.: WA-005233-8 Expiration Date:

Department for a State Waste Discharge Permit within thirty (30) days of such change.

D. Duty to Enforce Discharge Prohibitions

- 1. In accordance with 40 CFR 403.5(a), the Permittee shall not authorize or knowingly allow the discharge of any pollutants into its POTW which cause pass through or interference, or which otherwise violates general or specific discharge prohibitions contained in 40 CFR Part 403.5 or WAC-173-216-060.
- 2. The Permittee shall not authorize or knowingly allow the introduction of any of the following into its treatment works:
 - a. Pollutants which create a fire or explosion hazard in the POTW (including, but not limited to waste streams with a closed cup flashpoint of less than 140 degrees Fahrenheit or 60 degrees Centigrade using the test methods specified in 40 CFR 261.21).
 - b. Pollutants which will cause corrosive structural damage to the POTW, but in no case discharges with pH lower than 5.0, or greater than 11.0 standard units, unless the works are specifically designed to accommodate such discharges.
 - c. Solid or viscous pollutants in amounts that could cause obstruction to the flow in sewers or otherwise interfere with the operation of the POTW.
 - d. Any pollutant, including oxygen demanding pollutants, (BOD, etc.) released in a discharge at a flow rate and/or pollutant concentration which will cause interference with the POTW.
 - e. Petroleum oil, nonbiodegradable cutting oil, or products of mineral origin in amounts that will cause interference or pass through.
 - f. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity which may cause acute worker health and safety problems.
 - g. Heat in amounts that will inhibit biological activity in the POTW resulting in interference but in no case heat in such quantities such that the temperature at the POTW headworks exceeds 40°C (104°F) unless the Department, upon request of the Permittee, approves, in writing, alternate temperature limits.
 - h. Any trucked or hauled pollutants, except at discharge points designated by the Permittee.
 - i. Wastewaters prohibited to be discharged to the POTW by the Dangerous Waste Regulations (Chapter 173-303 WAC), unless authorized under the Domestic Sewage Exclusion (WAC 173-303-071).



Page 19 of 29

Permit No.: WA-005233-8

Expiration Date:

3. All of the following are prohibited from discharge to the POTW unless approved in writing by the Department under extraordinary circumstances (such as a lack of direct discharge alternatives due to combined sewer service or the need to augment sewage flows due to septic conditions):

- a. Noncontact cooling water in significant volumes.
- b. Stormwater, and other direct inflow sources.
- c. Wastewaters significantly affecting system hydraulic loading, which do not require treatment, or would not be afforded a significant degree of treatment by the system.
- 4. The Permittee shall notify the Department if any industrial user violates the prohibitions listed in this section.

S7. RESIDUAL SOLIDS

The Department requires that the City measure the volume of accumulated sludge in the sludge storage lagoon. This measurement shall be taken the second quarter of 2009 and reported to the Department. The report shall be submitted to the Department by **June 30**, **2009**.

To prevent water quality problems the City is required in Special Condition S7. to manage all residual solids (grit, screenings, scum, sludge and solid waste) in accordance with the requirements of: (1) RCW 90.48.080 and Water Quality Standards; (2) applicable sections of 40 CFR Part 503 and Chapter 173-308 WAC, "Biosolids Management"; and (3) applicable sections of Chapter 173-304 WAC, "Minimum Functional Standards for Solid Waste Handling."

The final use and disposal of biosolids shall be done in accordance with Chapter 173-308 WAC ("Biosolids Management"), 40 CFR Part 503, and under coverage of the State general permit for biosolids management. The disposal of solid waste, other than biosolids, is regulated by the local jurisdictional health department in accordance with State solid waste regulations.

S8. APPLICATION FOR PERMIT RENEWAL

The Permittee shall submit an application for renewal of this permit by **365 days (one year)** from the expiration date.



Page 20 of 29

Permit No.: WA-005233-8

Expiration Date:

S9. COMPLIANCE SCHEDULE

The Permittee shall conduct chemical analyses of effluent and sludge samples collected from the wastewater treatment system for the presence of DDT and PCB and submit the results of the analysis to the Department no later than May 15, 2006. In the event that DDT and PCB are not detected in both the sludge and effluent samples, the Permittee is required to sample and retest the sludge only and submit the results to the Department by **December 15, 2006**. In the event of a second negative sludge sample test the Schedule of Compliance is suspended and the Permittee shall test the effluent and sludge in 2010 and submit the results of the analysis with its application for permit renewal.

In the event of a positive test for DDT and/or PCB in either the sludge or effluent samples, the Permittee shall conduct a DDT/PCB Source Identification and Reduction Evaluation. The goals of the study are: (1) to identify the source of the pollutants, (2) to identify their entry point into the POTW, and (3) to develop measure to reduce and, if possible, eliminate these substances from the POTW. The Evaluation shall consist of three (3) parts: a Scope of Work, biannual (2/year) Progress Reports and a Final Report.

A. Scope of Work

The Scope of Work shall consist of a detailed plan describing the methodology the City will use to identify the source(s) of DDT and PCB to the POTW. The Scope of Work shall also contain a schedule of the study's milestones and a monitoring plan, detailed to the extent possible. The Scope of Work shall be submitted to the Department for review and approval by March 31, 2007.

B. Progress Reports

The Permittee shall submit progress reports that describe: (1) the progress made since the previous report in detail and (2) the progress made to fulfill the goals of the study, in more general terms. Progress Reports shall be submitted to the Department by **March 15**th and **September 15**th of each year to begin on **September 15, 2007**. Progress Reports shall continue to be submitted until: (1) the Final Report is approved by the Department, (2) the end of the permit cycle, or, (3) the Permittee is directed by the Department to stop submitting reports, whichever comes first.

C. Final Report

The DDT/PCB Source Identification and Reduction Evaluation Final Report shall describe, comprehensively and in detail, (1) the goals of the study, (2) the




Page 21 of 29

Permit No.: WA-005233-8

Expiration Date:

methodologies used, and, (3) the results of the study. Specifically, (3) shall describe suspected and identified sources of contamination, their entry points to the POTW, and any progress made to reduce or eliminate the contaminants from the POTW. The Final Report shall be submitted to the Department by **September 15, 2009.**





Page 22 of 29

Permit No.: WA-005233-8

Expiration Date:


GENERAL CONDITIONS

G1. SIGNATORY REQUIREMENTS

All applications, reports, or information submitted to the Department shall be signed and certified.

- A. All permit applications shall be signed by either a principal executive officer or a ranking elected official.
- B. All reports required by this permit and other information requested by the Department shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - 1. The authorization is made in writing by a person described above and submitted to the Department.
 - 2. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.)
- C. Changes to authorization. If an authorization under paragraph B.2 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the requirements of paragraph B.2 above must be submitted to the Department prior to or together with any reports, information, or applications to be signed by an authorized representative.
- D. Certification. Any person signing a document under this section shall make the following certification:

I certify under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gathered and evaluated the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.





Page 23 of 29

Permit No.: WA-005233-8

Expiration Date:

G2. RIGHT OF INSPECTION AND ENTRY

The Permittee shall allow an authorized representative of the Department, upon the presentation of credentials and such other documents as may be required by law:

- A. To enter upon the premises where a discharge is located or where any records must be kept under the terms and conditions of this permit.
- B. To have access to and copy at reasonable times and at reasonable cost any records required to be kept under the terms and conditions of this permit.
- C. To inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, methods, or operations regulated or required under this permit.
- D. To sample or monitor at reasonable times any substances or parameters at any location for purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act.

G3. PERMIT ACTIONS

This permit may be modified, revoked and reissued, or terminated either at the request of any interested person (including the Permittee) or upon the Department's initiative. However, the permit may only be modified, revoked and reissued, or terminated for the reasons specified in 40 CFR 122.62, 122.64 or WAC 173-220-150 according to the procedures of 40 CFR 124.5.

- A. The following are causes for terminating this permit during its term, or for denying a permit renewal application:
 - 1. Violation of any permit term or condition.
 - 2. Obtaining a permit by misrepresentation or failure to disclose all relevant facts.
 - 3. A material change in quantity or type of waste disposal.
 - 4. A determination that the permitted activity endangers human health or the environment, or contributes to water quality standards violations and can only be regulated to acceptable levels by permit modification or termination [40 CFR part 122.64(3)].
 - 5. A change in any condition that requires either a temporary or permanent reduction, or elimination of any discharge or sludge use or disposal practice controlled by the permit [40 CFR part 122.64(4)].
 - 6. Nonpayment of fees assessed pursuant to RCW 90.48.465.
 - 7. Failure or refusal of the Permittee to allow entry as required in RCW 90.48.090.



Page 24 of 29

Permit No.: WA-005233-8


Expiration Date:

B. The following are causes for modification but not revocation and reissuance except when the Permittee requests or agrees:

- 1. A material change in the condition of the waters of the state.
- 2. New information not available at the time of permit issuance that would have justified the application of different permit conditions.
- 3. Material and substantial alterations or additions to the permitted facility or activities which occurred after this permit issuance.
- 4. Promulgation of new or amended standards or regulations having a direct bearing upon permit conditions, or requiring permit revision.
- 5. The Permittee has requested a modification based on other rationale meeting the criteria of 40 CFR part 122.62.
- 6. The Department has determined that good cause exists for modification of a compliance schedule, and the modification will not violate statutory deadlines.
- 7. Incorporation of an approved local pretreatment program into a municipality's permit.
- C. The following are causes for modification or alternatively revocation and reissuance:
 - 1. Cause exists for termination for reasons listed in A1 through A7 of this section, and the Department determines that modification or revocation and reissuance is appropriate.
 - 2. The Department has received notification of a proposed transfer of the permit. A permit may also be modified to reflect a transfer after the effective date of an automatic transfer (General Condition G8) but will not be revoked and reissued after the effective date of the transfer except upon the request of the new Permittee.

G4. REPORTING PLANNED CHANGES

The Permittee shall, as soon as possible, but no later than 60 days prior to the proposed changes, give notice to the Department of planned physical alterations or additions to the permitted facility, production increases, or process modification which will result in: 1) the permitted facility being determined to be a new source pursuant to 40 CFR 122.29(b); 2) a significant change in the nature or an increase in quantity of pollutants discharged; or 3) a significant change in the Permittee's sludge use or disposal practices. Following such notice, and the submittal of a new application or supplement to the existing application, along with required engineering plans and reports, this permit may be modified, or revoked and reissued pursuant to 40 CFR 122.62(a) to specify and limit any pollutants not previously limited. Until such modification is effective, any new or increased discharge in excess of





Page 25 of 29

Permit No.: WA-005233-8

Expiration Date:

permit limits or not specifically authorized by this permit constitutes a violation of the terms and conditions of this permit.

G5. PLAN REVIEW REQUIRED

Prior to constructing or modifying any wastewater control facilities, an engineering report and detailed plans and specifications shall be submitted to the Department for approval in accordance with Chapter 173-240 WAC. Engineering reports, plans, and specifications shall be submitted at least 180 days prior to the planned start of construction unless a shorter time is approved by Ecology. Facilities shall be constructed and operated in accordance with the approved plans.

G6. COMPLIANCE WITH OTHER LAWS AND STATUTES

Nothing in this permit shall be construed as excusing the Permittee from compliance with any applicable federal, state, or local statutes, ordinances, or regulations.

G7. TRANSFER OF THIS PERMIT

In the event of any change in control or ownership of facilities from which the authorized discharge emanate, the Permittee shall notify the succeeding owner or controller of the existence of this permit by letter, a copy of which shall be forwarded to the Department.

A. Transfers by Modification

Except as provided in paragraph (B) below, this permit may be transferred by the Permittee to a new owner or operator only if this permit has been modified or revoked and reissued under 40 CFR 122.62(b)(2), or a minor modification made under 40 CFR 122.63(d), to identify the new Permittee and incorporate such other requirements as may be necessary under the Clean Water Act.

B. Automatic Transfers

This permit may be automatically transferred to a new Permittee if:

- 1. The Permittee notifies the Department at least 30 days in advance of the proposed transfer date.
- 2. The notice includes a written agreement between the existing and new Permittees containing a specific date transfer of permit responsibility, coverage, and liability between them.



Page 26 of 29

Permit No.: WA-005233-8

Expiration Date:

3. The Department does not notify the existing Permittee and the proposed new Permittee of its intent to modify or revoke and reissue this permit. A modification under this subparagraph may also be minor modification under 40 CFR 122.63. If this notice is not received, the transfer is effective on the date specified in the written agreement.

G8. REDUCED PRODUCTION FOR COMPLIANCE

The Permittee, in order to maintain compliance with its permit, shall control production and/or all discharges upon reduction, loss, failure, or bypass of the treatment facility until the facility is restored or an alternative method of treatment is provided. This requirement applies in the situation where, among other things, the primary source of power of the treatment facility is reduced, lost, or fails.

G9. REMOVED SUBSTANCES

Collected screenings, grit, solids, sludges, filter backwash, or other pollutants removed in the course of treatment or control of wastewaters shall not be resuspended or reintroduced to the final effluent stream for discharge to state waters.

G10. DUTY TO PROVIDE INFORMATION

The Permittee shall submit to the Department, within a reasonable time, all information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The Permittee shall also submit to the Department upon request, copies of records required to be kept by this permit [40 CFR 122.41(h)].

G11. OTHER REQUIREMENTS OF 40 CFR

All other requirements of 40 CFR 122.41 and 122.42 are incorporated in this permit by reference.

G12. ADDITIONAL MONITORING

The Department may establish specific monitoring requirements in addition to those contained in this permit by administrative order or permit modification.



Page 27 of 29

Permit No.: WA-005233-8

Expiration Date:

G13. PAYMENT OF FEES

The Permittee shall submit payment of fees associated with this permit as assessed by the Department.

G14. PENALTIES FOR VIOLATING PERMIT CONDITIONS

Any person who is found guilty of willfully violating the terms and conditions of this permit shall be deemed guilty of a crime, and upon conviction thereof shall be punished by a fine of up to \$10,000 and costs of prosecution, or by imprisonment in the discretion of the court. Each day upon which a willful violation occurs may be deemed a separate and additional violation.


Any person who violates the terms and conditions of a waste discharge permit shall incur, in addition to any other penalty as provided by law, a civil penalty in the amount of up to \$10,000 for every such violation. Each and every such violation shall be a separate and distinct offense, and in case of a continuing violation, every day's continuance shall be deemed to be a separate and distinct violation.

G15. UPSET

Definition – "Upset" means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the Permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.

An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of the following paragraph are met.

A Permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that: 1) an upset occurred and that the Permittee can identify the cause(s) of the upset; 2) the permitted facility was being properly operated at the time of the upset; 3) the Permittee submitted notice of the upset as required in condition S3.E; and 4) the Permittee complied with any remedial measures required under S5 of this permit. In any enforcement proceeding the Permittee seeking to establish the occurrence of an upset has the burden of proof.





Page 28 of 29

Permit No.: WA-005233-8

Expiration Date:

G16. PROPERTY RIGHTS

This permit does not convey any property rights of any sort, or any exclusive privilege.

G17. DUTY TO COMPLY

The Permittee shall comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

G18. TOXIC POLLUTANTS

tonasket p 1-23-06

The Permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Clean Water Act for toxic pollutants within the time provided in the regulations that establish those standards or prohibitions, even if this permit has not yet been modified to incorporate the requirement.

G19. PENALTIES FOR TAMPERING

The Clean Water Act provides that any person who falsifies, tampers with, or knowingly renders inaccurate any monitoring device or method required to be maintained under this permit shall, upon conviction, be punished by a fine of not more than \$10,000 per violation, or by imprisonment for not more than two years per violation, or by both. If a conviction of a person is for a violation committed after a first conviction of such person under this Condition, punishment shall be a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or by both.

G20. REPORTING ANTICIPATED NON-COMPLIANCE

The Permittee shall give advance notice to the Department by submission of a new application or supplement thereto at least 180 days prior to commencement of such discharges, of any facility expansions, production increases, or other planned changes, such as process modifications, in the permitted facility or activity which may result in noncompliance with permit limits or conditions. Any maintenance of facilities, which might necessitate unavoidable interruption of operation and degradation of effluent quality, shall be scheduled during noncritical water quality periods and carried out in a manner approved by the Department.



Page 29 of 29

Permit No.: WA-005233-8

Expiration Date:

G21. REPORTING OTHER INFORMATION

Where the Permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application, or in any report to the Department, it shall promptly submit such facts or information.

G22. COMPLIANCE SCHEDULES

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.

